



**GOLDER RANCH FIRE DISTRICT
GOVERNING BOARD
PUBLIC NOTICE**

At the April 9, 2019 Golder Ranch Fire District Governing Board Meeting, the Governing Board approved the posting of two additional local amendments to the previously adopted 2018 International Fire Code (IFC) with local amendments. This serves as a public notice and will be posted in four public places within the District. These additional amendments to the IFC will remain posted for twenty days, prior to the public hearing on May 14 at 9:00 a.m., pursuant to ARS 48-805.02.

The four posting locations are:

Golder Ranch Fire District Administration
3885 E. Golder Ranch Drive
Tucson, Arizona 85739

Golder Ranch Fire District Fire and Life Safety
1175 W. Magee Road
Tucson, Arizona 85704

Golder Ranch Fire District Station 377
355 E. Linda Vista Boulevard
Tucson, Arizona 85704

Golder Ranch Fire District Station 373
63735 E. SaddleBrooke Boulevard
Tucson, AZ 85739

The entire 2018 International Fire Code (IFC) with local amendments are provided in a paper format and available on request at all of the above listed Golder Ranch Fire District locations.

Posted By: Brooke Painter

Date: April 11, 2019

**Golder Ranch Fire District
Fire and Life Safety Division
2018 International Fire Code
Local Amendments**

~~and throughout all stories from the Group A-3 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists: DELETE the remainder of the section.~~

Section 903.2.1.4 Group A-4: Is hereby **AMENDED** to read: An automatic sprinkler system shall be provided throughout all stories of a building containing Group A-4 occupancies. ~~and throughout all stories from the Group A-4 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists: DELETE the remainder of the section.~~

Section 903.2.1.5 Group A-5: Is hereby **AMENDED** to read: An automatic sprinkler system shall be provided for all enclosed Group A-5 amusement park structures in accordance with Section 914.7, stadiums and accessory use areas in excess of 1000 square feet (92 m²).

Section 903.2.2 Ambulatory care facilities: Is hereby **AMENDED** to read: An automatic sprinkler system shall be installed throughout all floors of a building containing an ambulatory care facility. ~~where either of the following conditions exist at any time: DELETE the remainder of the section up to the exception. The exception remains.~~

ADD a new subsection:

Section 903.2.3a Group B: An automatic sprinkler system shall be provided for all floors of a building containing Group B occupancies.

Section 903.2.3 Group E: Is hereby **AMENDED** to read: An automatic sprinkler system shall be provided for all floors of a building containing Group E occupancies. ~~as follows: DELETE the remainder of the section.~~

Section 903.2.4 Group F-1: Is hereby **AMENDED** to read: An automatic sprinkler system shall be provided throughout all stories of a building containing a Group F-1 occupancies. ~~where one of the following conditions exists: DELETE the remainder of the section.~~

Section 903.2.4.1 Woodworking operations: Is hereby **AMENDED** to read: An automatic sprinkler system shall be provided throughout all Group F-1 occupancy fire areas that contain woodworking operations ~~in excess of 2,500 square feet (232 m²) in area~~ that generate finely divided combustible waste or use finely divided combustible materials.

Section 903.2.5.3 Pyroxylin plastics: Is hereby **AMENDED** to read: An automatic sprinkler system shall be provided in buildings, or portion thereof, where cellulose nitrate film or Pyroxylin plastics are manufactured, stored or handled ~~in quantities exceeding 100 pounds (45 kg).~~

Section 903.2.6 Group I: Is hereby **AMENDED** to read:

HAZARDOUS MATERIALS – GENERAL PROVISIONS

No Changes

CHAPTER 51 AEROSOLS

No Changes

CHAPTER 52 RESERVED

CHAPTER 53 COMPRESSED GASES

~~No Changes~~

Section 5307.3 AMENDED BY DELETING (Insulated) Liquid Carbon Dioxide Systems Used In Beverage Dispensing Applications: **(Insulated)** L(1)iquid carbon dioxide systems with more than 100 pounds (45.4kg) of carbon dioxide used in beverage dispensing applications shall comply with Section 5307.3.1.

CHAPTER 54 CORROSIVE MATERIALS

No Changes

CHAPTER 55 CRYOGENIC FLUIDS

No Changes

CHAPTER 56 EXPLOSIVES AND FIREWORKS

No Changes

CHAPTER 57 FLAMMABLE AND COMBUSTIBLE LIQUIDS

Section 5704.2.9.6.1 is AMENDED by ADDING: Locations where above-ground tanks are prohibited. The storage of Class I and II liquids in above-ground tanks outside of buildings, **THAT EXCEED 5,000 GALLONS (18,927 LITERS) IN AGGREGATE VOLUME,** is prohibited within the **BOUNDARIES OF THE TOWN OF ORO VALLEY** ~~limits established by law as the limits of districts in which such storage is prohibited (JURISDICTION TO SPECIFY).~~