



# GOLDER RANCH FIRE DISTRICT

## Firefighter I and II Practical Skill Sheets

### Hose Deployment 2.5" Triple Load

**Standards:**

NFPA 1001: 4.3.8 (2019 Edition)

NFPA 1001: 4.3.13 (2019 Edition)

**Task/Performance Outcome:**

The firefighter shall be given the objective of deploying a 2.5" hose line to a specific location. Upon completing this objective, the firefighter shall be ready to operate the hose line from the exterior of a structure on their captain's instruction.

**Required Personal Protective Equipment (PPE):**

Full turnout ensemble, full SCBA ensemble, SCBA mask donned, waits on order to go on air (unless in the IDLH).

**Required Equipment:**

- Radio for each firefighter
- Flashlight for each firefighter
- Irons to door
- Axe or Halligan Interior
- Thermal Imaging Camera (Captain)

**Critical Fail Criteria:**

Failure consists of the following:

- Failure to be seated and belted upon arrival.
- Failure to wear the required PPE.
- Failure to physically address their accountability on the passport of their assigned apparatus.
- Failure to exit the apparatus safely and with three points of contact.
- Glaring, gross errors, as documented by the evaluator.
- An apparent lack of efficiency and comfort with the activity, as documented by the evaluator.
- Less than 80% of available points scored.

**Evolution Details:**

The candidate will be assigned to a crew. The evaluator will advise the candidate on which hose to deploy off a given truck. The candidate must deploy the hose line off the truck by themselves, unless the candidate is instructed to perform an alley pull by the evaluator. Unless specified by the evaluator, the candidate can configure the hose in a straight line or in a Keenan Loop. The candidate must be on the nozzle.



# GOLDER RANCH FIRE DISTRICT

## Firefighter I and II Practical Skill Sheets

### Hose Deployment 2.5" Triple Load

| Actions  | Points Available | Points Earned |
|--|------------------|---------------|
| <b>Time starts upon instructor prompt or when first boot hits the ground.</b>                |                  |               |
| Safely selects & removes correct hose line   | 1                |               |
| Safely removes entire hose from apparatus  | 1                |               |
| Deploys loop away from the fire attack location and takes nozzle to the fire attack location | 1                |               |
| Flakes out hose near the fire attack location for ease of future movements if necessary      | 1                |               |
| Secures nozzle and signals for water   | 1                |               |
| Adjusts nozzle pattern then bleeds for five seconds  | 2                |               |
| Turns on SCBA, dons mask, and goes on air if in IDLH   | 1                |               |
| <b>Time stops when candidate has completed the above criteria</b>                            | 3                |               |
| <b>Total Points (9/11 to pass)</b>   | 11               |               |

1:30 or less = 3 points

1:3 - 1:45 = 2 points

1:46 - 2:00 = 1 point

2:01 or more = Fail

Cancer Reduction Cab (CRC) Suppression Apparatus Configuration: Add 30 seconds to each category.

Candidate: \_\_\_\_\_ Evaluator: \_\_\_\_\_ Total: \_\_\_\_\_/11

Circle one:

Pass/Fail on points/Fail on critical criteria.

Comments \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_