



GOLDER RANCH FIRE DISTRICT

Firefighter I and II Practical Skill Sheets

Hose Deployment High-Rise Pack

Standards:

NFPA 1001: 4.3.13 (2019 Edition)

NFPA 1001: 4.3.10 (2019 Edition)

Task/Performance Outcome:

The candidate will be given the objective of deploying a High-Rise pack to a specific location and have the High-Rise pack in a ready state to be charged. Upon completing this evolution, the candidate and their crew shall have an operationally ready horizontal standpipe and 100' 1.75" High-Rise Pack charged, flushed, and shaped appropriately.

Required Personal Protective Equipment (PPE):

Full turnout ensemble, full SCBA ensemble, SCBA mask donned, waits on order to go on air (unless in the IDLH).

Required Equipment:

- Radio for each firefighter
- Flashlight for each firefighter
- Irons to door
- Axe or Halligan Interior
- Thermal Imaging Camera (Captain)

Critical Fail Criteria:

Failure consists of the following:

- Failure to be seated and belted upon arrival.
- Failure to wear the required PPE.
- Failure to physically address their accountability on the passport of their assigned apparatus.
- Failure to exit the apparatus safely and with three points of contact.
- Glaring, gross errors, as documented by the evaluator.
- An apparent lack of efficiency and comfort with the activity, as documented by the evaluator.
- Less than 80% of available points scored.

Evolution Details:

The candidate will be assigned to a crew. The evaluator will advise the candidate of the location the High-Rise Pack will need to be deployed. Once the High-Rise pack is safely deployed to the predetermined location, the candidate will spread out the pack for effective deployment. The High-Rise Pack is connected to the gated wye on the Horizontal Standpipe. Once the candidate on the High-Rise Pack is ready, they will call for water while securing the nozzle.



GOLDER RANCH FIRE DISTRICT

Firefighter I and II Practical Skill Sheets

Hose Deployment High-Rise Pack

Actions	Points Available	Points Earned
Time starts upon instructor prompt or when first boot hits the ground.		
Safely removes one High-Rise Pack from the apparatus compartment, placing one on their shoulder and leaving one at the truck	1	
Safely deploys 1.75" High-Rise Pack to the appropriate location	1	
Removes straps from the High-Rise Pack	1	
Spreads out High-Rise Pack for proper deployment	1	
Signals for water to the firefighter on the Horizontal Standpipe with gated wye, while securing the nozzle	1	
Adjusts nozzle pattern and flushes for five seconds	2	
Turns on SCBA, dons mask, and goes on air if in IDLH	1	
Time stops when candidate has completed the above criteria	3	
Total Points (9/11 to pass)	11	

2:00 or less = 3 points

2:01 – 2:20 = 2 points

2:21 - 2:40 = 1 point

2:41 or more = Fail

Cancer Reduction Cab (CRC) Suppression Apparatus Configuration: Add 30 seconds to each category.

Candidate: _____ Evaluator: _____ Total: _____/11

Circle one:

Pass/Fail on points/Fail on critical criteria

Comments _____

