



GOLDER RANCH FIRE DISTRICT

Firefighter I and II Practical Skill Sheets

Hose Deployment Horizontal Standpipe

Standards:

NFPA 1001: 4.3.13 (2019 Edition)

NFPA 1001: 4.3.10 (2019 Edition)

Task/Performance Outcome:

The candidate shall be given the objective of deploying a Horizontal Standpipe to a specific location.

Upon completing the evolution, the candidate and their crew shall have an operationally ready horizontal standpipe and 100' 1.75" High-Rise Pack charged, flushed, and shaped appropriately.

Required Personal Protective Equipment (PPE):

Full turnout ensemble, full SCBA ensemble, SCBA mask donned, waits on order to go on air (unless in the IDLH).

Required Equipment:

- Radio for each firefighter
- Flashlight for each firefighter
- Irons to door
- Axe or Halligan Interior
- Thermal Imaging Camera (Captain)

Critical Fail Criteria:

Failure consists of the following:

- Failure to be seated and belted upon arrival.
- Failure to wear the required PPE.
- Failure to physically address their accountability on the passport of their assigned apparatus.
- Failure to exit the apparatus safely and with three points of contact.
- Glaring, gross errors, as documented by the evaluator.
- An apparent lack of efficiency and comfort with the activity, as documented by the evaluator.
- Less than 80% of available points scored.

Evolution Details:

The candidate will be assigned to a crew. The evaluator will advise the candidate of the location the Horizontal Standpipe will need to be deployed. Once safely deployed to the predetermined location, the candidate will call for water securing the gated wye. The High-Rise pack will be connected and then charged when the firefighter on the nozzle calls for water. The candidate and crew must don their masks and be ready to go on air to make entry.



GOLDER RANCH FIRE DISTRICT

Firefighter I and II Practical Skill Sheets

Hose Deployment Horizontal Standpipe

Actions	Points Available	Points Earned
Time starts upon instructor prompt or when first boot hits the ground.		
Safely deploys the 2.5" Horizontal Standpipe with pre-connected wye to the appropriate location	1	
Ensures gated wye is closed, signals for water, charging the 2.5" Horizontal Standpipe, while using body weight to secure the hose line	1	
Ensures High-Rise pack is attached to gated wye of Horizontal Standpipe	1	
Maintains control of the wye while the High-Rise Pack is being charged. *** If the wrong valve on the wye is opened, but the candidate immediately addresses it in a safe manner, they lose one (1) point*** ***If the candidate fails to control the valves and/or unsafely charges the High-Rise Pack, it is a critical failure***	2	
Turns on SCBA, dons mask, and goes on air if in IDLH	1	
Time stops when candidate has completed the above criteria	3	
Total Points (8/9 to pass)	9	

2:00 or less = 3 points

2:01 – 2:20 = 2 points

2:21 - 2:40 = 1 point

2:41 or more = Fail

Cancer Reduction Cab (CRC) Suppression Apparatus Configuration: Add 30 seconds to each category.

Candidate: _____ Evaluator: _____ Total: _____/12

Circle one:

Pass/Fail on points/Fail on critical criteria

Comments _____

